

Report of Analysis

3-14
3

Client Sample ID:	GIANT STEP PRE-SCHOOL 246 E. MAIN ST	Date Sampled:	06/27/17
Lab Sample ID:	D95389-14	Date Received:	06/30/17
Matrix:	DW - Drinking Water	Percent Solids:	n/a
Project:	PWSID CO0152666 Town of Rangely		

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Copper	0.024	1.3	0.0020	mg/l	1	07/03/17	07/05/17 MR	EPA 200.8 ¹	EPA 200.8 ²
Lead	<0.00050	0.015	0.00050	mg/l	1	07/03/17	07/05/17 MR	EPA 200.8 ¹	EPA 200.8 ²

(1) Instrument QC Batch: MA8714

(2) Prep QC Batch: MP22285

Results Reviewed. No hits on lead or copper.

*OK
PCR*

RL = Reporting Limit
MCL = Maximum Contamination Level (40 CFR 141)