

Report of Analysis

Page 1 of 1

Client Sample ID: GIANT STEP PRE-SCHOOL 246 E. MAIN ST

Lab Sample ID: D95389-14

Matrix: DW - Drinking Water

Date Sampled: 06/27/17

Date Received: 06/30/17

Percent Solids: n/a

Project: PWSID CO0152666 Town of Rangely

Total Metals Analysis

Analyte	Result	MCL	RL	Units	DF	Prep	Analyzed By	Method	Prep Method
Copper	0.024	1.3	0.0020	mg/l	1	07/03/17	07/05/17	MR	EPA 200.8 ¹
Lead	< 0.00050	0.015	0.00050	mg/l	1	07/03/17	07/05/17	MR	EPA 200.8 ¹

(1) Instrument QC Batch: MA8714

(2) Prep QC Batch: MP22285

Results Reviewed. No hits on lead or copper.

OK
PCR

RL = Reporting Limit

MCL = Maximum Contamination Level (40 CFR 141)